

28/01/2011

Argyll & Bute Council
Development Services Milton House
Milton Avenue
Dunoon
PA23 7DU
□□□□□

SCOTTISH WATER

Customer Connections
419 Balmore Road
Glasgow
G22 6NU

Customer Support Team
T: 0141 355 5511
F: 0141 355 5386
W: www.scottishwater.co.uk
E: connections@scottishwater.co.uk

Dear Sir/Madam

PLANNING APPLICATION NUMBER: 10/02077/PP
DEVELOPMENT: Land North West Of Ardare Colintrave Argyll And Bute
OUR REFERENCE: 542915
PROPOSAL: Erection of dwellinghouse, formation of vehicular access and installation of septic tank

Please quote our reference in all future correspondence

In terms of planning consent, Scottish Water does not object to this planning application. However, please note that any planning approval granted by the Local Authority does not guarantee a connection to our infrastructure. Approval for connection can only be given by Scottish Water when the appropriate application and technical details have been received. Approval for connection can only be given by Scottish Water when the appropriate application and technical details have been received.

There are no public sewers in the vicinity of the proposed development.

Dhu Loch Water Treatment Works currently has capacity to service this proposed development.

Water Network – Our initial investigations have highlighted there may be a requirement for the Developer to carry out works on the local network to ensure there is no loss of service to existing customers.

The Developer should discuss the implications directly with Scottish Water.

In some circumstances, it may be necessary for the Developer to fund works on existing infrastructure to enable their development to connect. Should we become aware of any issues such as flooding, low pressure, etc the Developer will require to fund works to mitigate the effect of the development on existing customers. Scottish Water can make a contribution to these costs through Reasonable Cost funding rules.

Scottish Water's current minimum level of service for water pressure is 1.0 bar or 10m head at the customer's boundary internal outlet. Any property which cannot be adequately serviced from the available pressure may require private pumping arrangements installed, subject to compliance with the current water byelaws. If the developer wishes to enquire about Scottish Water's procedure for checking the water pressure in the area then they should write to the Customer Connections department at the above address.

It is possible this proposed development may involve building over or obstruct access to existing Scottish Water infrastructure. On receipt of an application Scottish Water will provide advice that will require to be implemented by the developer to protect our existing apparatus.

Should the developer require information regarding the location of Scottish Water infrastructure they should contact our Property Searches Department, Bullion House, Dundee, DD2 5BB. Tel – 0845 601 8855.

If the developer requires any further assistance or information on our response, please contact me on the above number or alternatively additional information is available on our website: www.scottishwater.co.uk.

Yours faithfully

Shabana Jamil
Customer Connections Administrator
Tel: 0141 355 5045
shabana.jamil@scottishwater.co.uk