



17/02/2014

Argyll & Bute Council
Planning Services 67 Chalmers Street
Ardishaig
PA30 8DX

SCOTTISH WATER

Customer Connections
The Bridge
Buchannan Gate Business Park
Cumbernauld Rd
Stepps
G33 6FB

Tel – 0141 414 7660

Dear Sir Madam

PLANNING APPLICATION NUMBER: 14/00031/PP
DEVELOPMENT: Isle of Islay Bowmore
OUR REFERENCE: 649206

Please quote our reference in all future correspondence

Scottish Water has no objection to this planning application. This response is made based on the information available to us at this time and does not guarantee a connection to Scottish Water's infrastructure. A separate application should be submitted to us made for connection to our infrastructure after full planning has been granted.

Torra Water Treatment Works currently has capacity to service this proposed development.

Bowmore Waste Water Treatment Works currently has capacity to service this proposed development.

In some circumstances it may be necessary for the Developer to fund works on existing infrastructure to enable their development to connect. Should we become aware of any issues such as flooding, low pressure, etc the Developer will be required to fund works to mitigate the effect of the development on existing customers. Scottish Water can make a contribution to these costs through Reasonable Cost funding rules.

A totally separate drainage system will be required with the surface water discharging to a suitable outlet. Scottish Water requires a sustainable urban drainage system (SUDS) as detailed in Sewers for Scotland 2 if the system is to be considered for adoption.

Scottish Water's current minimum level of service for water pressure is 1.0 bar or 10m head at the customer's boundary internal outlet. Any property which cannot be adequately serviced from the available pressure may require private pumping arrangements installed, subject to compliance with the current water byelaws. If the developer wishes to enquire about Scottish Water's procedure for checking the water pressure in the area then they should write to the Customer Connections department at the above address.

If the connection to public sewer and/or water main requires to be laid through land out-with public ownership, the developer must provide evidence of formal approval from the affected landowner(s). This should be done through a deed of servitude.

Should the developer require information regarding the location of Scottish Water infrastructure they should contact our Property Searches Department, Bullion House, Dundee, DD2 5BB. Tel – 0845 601 8855.

If the developer requires any further assistance or information on our response, please contact me on the above number or alternatively additional information is available on our website:
www.scottishwater.co.uk.

Yours faithfully

Janine Franssen
Customer Connections Administrator