



NOTES :-

1. PROPOSED SMOKE & HEAT DETECTORS MAINS WIRED ON AN INDEPENDENT SINGLE FINAL CIRCUIT AND INTERCONNECTED WITH BATTERY BACK-UP CAPABLE OF 72 HOURS BACK-UP WHILE GIVING AN AUDIBLE WARNING. CEILING MOUNTING, MIN. 300mm AWAY FROM A LIGHT FITTING AND WALL AND NOT DIRECTLY ABOVE ANY HEATER OR AIR CON. OUTLET. ALL PROVISIONS IN LINE WITH BS5839:PART 1:2013 FOR A GRADE D TYPE L3 SYSTEM IN ACCORDANCE WITH BUILDING REGS.
2. FIRE EXTINGUISHERS WALL MOUNTED ON WALL ABOVE SINK :-
 - MONOAMMONIUM PHOSPHATE OR SODIUM BICARBONATE CLASS C RATED FIRE EXTINGUISHER FOR FIRES INVOLVING LIVE ELECTRICAL EQUIPMENT
 - POWDER FIRE EXTINGUISHER FOR FIRES INVOLVING FLAMMABLE LIQUIDS, GAS OR ELECTRICAL FIRES
 - FIRE BLANKET
3. SINGLE STEP 200mm HIGH
4. ALCOHOL DISPLAY SHELVING - 1.7m LONG x 1.3m HIGH x 0.225m WIDE
5. DRINKS FRIDGE - 0.9m LONG x 0.515m WIDE x 1.82m HIGH

				PROJECT			
				Shop at 92 High Street, Rothesay, Isle of Bute. PA20 9BN.			
Rev.	Amendment	By	Date	Drawn	GH	Scale	1:50
TITLE				Date	08.02.20	Drg. No.	048-007
Layout Plan							