



**GENERAL NOTES :**

Fire Warning System to comply with British Standard 5829:Part 1: 2002.

Emergency Lighting System to comply with British Standard 5266:Part 1:1999 ( Maintained - 2 hour duration ) and BS EN 1838:1999 ( or BS 5266-7:1999 )

Fire Fighting Equipment to comply with British Standard EN3, British Standard 7863: 1996, British Standard 5306-3:2000 and British Standard 5306-8:2000.

Signs and Notices to comply with the Health and Safety ( Safety Signs and Signals ) Regulations 1996 and / or British Standard 5852:Part 1:1990.

**Fire Legend:**

- <sub>WE</sub> Water Extinguisher
- <sub>CDE</sub> Carbon Dioxide Extinguisher
- ⊕<sub>SD</sub> Smoke Detector
- 🔊 Fire Alarm Sounder
- 🧯 Fire Blanket
- 🚪 Illuminated Fire Exit Sign
- ⊙ Break Glass - Fire Alarm - Call Point
- 📺 Fire Alarm Control Panel
- 🚪 Push Bar / Pad
- 🩹 First Aid Box (Wall Mounted)

**INTERNAL AREA**  
Extent of Property  
128.62m<sup>2</sup>

**EXTERNAL AREA**  
Extent of Customer Area  
Total Licensed Customer Area - 211m<sup>2</sup> (Hatched)  
Occupant Capacity of Licensed Premises - 191 Persons

REV. DATE DESCRIPTION  
A 2/8/22 Notes Added

JOB NO CP:646.  
DRG NO LP-01A  
CLIENT Oban Sailing Club.  
SCALE 1:100 @ A3.  
DATE March '19.

PROJECT TITLE Clubhouse,  
Gallanach Road, Oban,  
Argyll.  
DRAWING TITLE Licensing Plan

**cparchitects**  
Chartered Architects and Principal Designers  
110 George Street, Oban, Argyll. PA34 5NT  
T 01831 563 177 F 01831 563 234  
e-mail: mail@cparchitects.net website: www.cparchitects.net